


Current and Voltage Converter.

Phone: +1 561 779 5660 E-mail: Info@datexel.com - Web Site www.datexel.com

FEATURES

- Configurable input for voltage and current
- Configurable output in current or voltage
- Configurable by dip-switch or PC
- High accuracy
- On-field reconfigurable
- Galvanic isolation among the ways
- UL / CE mark
- Suitable for DIN rail mounting in compliance with EN-50022 and EN-50035



Isolated converter for voltage and current configurable by **Dip-Switch or PC**

DAT 4531 D











GENERAL DESCRIPTION

The isolated converter DAT 4531 D is able to measure voltage and current signals. In function of programming, the measured values are converted in a current or voltage signal. The device guarantees high accuracy and performances stability both versus time and temperature.

The programming is made by the dip-switch located in the window on the side of the enclosure. By means of dip-switches it is possible to select the input type and range and the output type without recalibrate the device.

Moreover, by Personal Computer the user can program all of the device's parameters for his own necessity.

The terminals of the current signal on input side must be only connected to active current loop.

The 1500 Vac galvanic isolation on all ways (input, output and power supply) eliminates the effects of all ground loops eventually existing and allows the use of the converter in heavy environmental conditions found in industrial applications.

The DAT 4531 D is in compliance with the Directive UL 61010-1 for US market and with the Directive CSA C22.2 No 61010-1 for the Canadian market.

It is housed in a plastic enclosure of 12.5 mm thickness suitable for DIN rail mounting in compliance with EN-50022 and EN-50035 standards.

USER INSTRUCTIONS

The connections must be made as shown in the section "Connections".


It is possible to configure the converter on field by dip-switch or Personal Computer as shown in the section "Programming". The configuration by dip-switches can be made also if the device is powered (note: after the configuration the device takes some seconds to provide the right output measure).

TECHNICAL SPECIFICATIONS (Typical at 25 °C and in nominal conditions)

INPUT				ОИТРИТ				POWER SUPPLY	
Input type	Min	Max	Min.Span	Output type	Min	Max	Min Span	Power supply voltage	18 30 Vdc
Voltage Current	0 V 0 mA	10 V 20 mA	1 V 1 mA	Current Voltage	0 mA 0 V	20 mA 10 V	4 mA 1 V	Reverse polarity protection 60 Vdc max Current consumption Current output 35 mA max.	
Accuracy (1) Volt the higher of ±0.1% f.s. and ± 2 mV mA the higher of ±0.1% f.s. and ± 6 uA				Voltage		7 uA 4 mV		Voltage output ISOLATION Among all the ways	20 mA max. 1500 Vac, 50 Hz, 1 min
Linearity (1) Volt, mA ± 0.05 % f.s.				Max. output value 22 mA or 10.6 V Min. output value 0 mA or -0.6 V		ENVIRONMENTAL CONDITIONS Operative Temperature -20°C +60°C UL Operative Temperature -10°C +60°C			
			Output load Resistance - R Current output Voltage output Short circuit current		kload $< 500 \Omega$ $> 10 K\Omega$ 26 mA max.		Storage Temperature Humidity (not condense Maximum Altitude Installation	2000 m Indoor	
Thermal drift (1) Full scale ± 0.01% / °C			Response time (10÷ 90%) about 100 ms			ms	IP Code IF Wiring w 0. Tightening Torque 0. Mounting in ra	2	
(1)referred to the input	Span (differen	ce between n	nax. and min.)					Emission UL US Standard Canadian Standard CCN Typology Classification	DIVIRONMENTS) EN 61000-6-2 EN 61000-6-4 JL 61010-1 CSA C22.2 No 61010-1 NRAQ/NRAQ7 Open Type device ndustrial Control Equipment E352854

PROGRAMMING


CONFIGURATION BY DIP-SWITCHES



1) Open the suitable door on the side of the device.

Refer to TAB.1

- 2) Set the input type by the dip-switch SW1 [1..4]
- 3) Set the output type by the dip-switch SW1 [6..8]
- 4) Set the options by the dip-switch SW1 [5]



NOTE:

- It is also possible to set the dip-switches using the wizard of the configuration software following the procedure described in the section "Configuration by PC" until the step 6 and clicking on "Switch".

DIP-SWITCH CONFIGURATION TABLES

TAB.1 - Settings

Input	Output	Options
SW1 1 2 3 4	SW1 678	SW1 <u>5</u> Out:
Default *	0÷20 mA	Direct
0÷20 mA	4÷20 mA	Reverse
4÷20 mA	0÷10 V	
0÷10 V	2 ÷10 V	
2÷10 V	0÷5 V	
0÷5 V	1 ÷5 V	
1÷5 ∨		

NOTES:

- * If the dip-switches SW1 [1..4] are all set in the position 0 ("Default"), the device will follow the configuration programmed by PC (Input and output type and options).
- * Eventual wrong dip-switches settings will be signalled by the blinking of the led "PWR".


CONFIGURATION BY PC

By software DATESOFT it is possible to:

- set the default programming of the device;
- program the options not available with the dip-switch;
- read, in real time, the input and output measures;
- follow the dip-switches configuration wizard.

To configure the device follow the next steps:

- 1) Power-on the device.
- 2) Open the protection plastic label on the front of the device.
- 3) Connect the interface PRODAT to the PC (COM port) and to the device (PGRM connector).
- 4) Open DATESOFT.
- 5) Select the COM port in use.
- 6) Click on "Open COM".
- 7) Click on "Program".
- 8) Set the programming data.
- 9) Click on "Write" to send the programming data to the device.



Warning: during these operations the device must always be powered and the TX/RX cable always connected. For information about DATESOFT refer to the software's user guide.

INSTALLATION INSTRUCTIONS

The device is suitable for fitting to DIN rails in the vertical position. For optimum operation and long life follow these instructions:

When the devices are installed side by side it may be necessary to separate them by at least 5 mm in the following cases:

- If panel temperature exceeds 45°C
- Use of high power supply value (> 27 Vdc).
- Use of output current.

Make sure that sufficient air flow is provided for the device avoiding to place raceways or other objects which could obstruct the ventilation slits. Moreover it is suggested to avoid that devices are mounted above appliances generating heat; their ideal place should be in the lower part of the panel.


Install the device in a place without vibrations.

Moreover it is suggested to avoid routing conductors near power signal cables (motors, induction ovens, inverters etc...) and to use shielded cable for connecting signals.


ISOLATION STRUCTURE



CONNECTIONS



POWER SUPPLY(*)



(*) Note: for UL installation the device must be powered using a power supply unit classified NEC class 2 or SELV

LIGHT SIGNALLING

LED	COLOUR	STATE	DESCRIPTION	
PWR	GREEN	ON	Device powered	
		OFF	Device not powered	
		BLINKING	Wrong dip-switches setting	

DIMENSIONS (mm)

